

EC type examination certificate
EU-Baumusterprüfbescheinigung

CE-0085CM0320
 Product Identification No.
 Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Distributor <i>Vertreiber</i>	Vaillant GmbH Berghauser Straße 40, D-42859 Remscheid
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Condensing combi water heater
Model <i>Modell</i>	VC/VCW ...(E-PL) ecoTEC exclusive
Countries of Destination <i>Bestimmungsländer</i>	PL
Test Reports <i>Prüfberichte</i>	type testing: K20582017B1 from 29.05.2017 (TRG)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-1 (01.01.2013)

Validity / File no. 21.04.2018 until 22.06.2027 / 17-0412-GEA
Gültigkeit / AZ



22.06.2017 Rie F-1/2

Date, Issued by, Sheet, Head of Certification Body
 Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EC Regulation



DVGW CERT GmbH
 Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
 53123 Bonn

Tel. +49 228 91 88 - 888
 Fax +49 228 91 88 - 993

www.dvgw-cert.com
 info@dvgw-cert.com

Elektrical Data 230 V AC, 50 Hz, IPX4D
Elektrische Daten

Appliance Categories <i>Geräte-kategorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
II2E LwLs3P	20,20,13, 30 mbar	PL	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
VC 256/5-7 (E-PL) ecoTEC exclusive	nominal heat output: 1,7...20,2; 3,6...20,2 (LPG) kW heat input (Hi): 1,9...20,4; 4,0...20,4 (LPG) kW	heat input (Hi) drinking water: 1,9...24,2 kW; 4,0...24,2 kW (LPG)
VC 306/5-7 (E-PL) ecoTEC exclusive	nominal heat output: 3,0...24,9; 3,7...24,9 (LPG) kW heat input (Hi): 3,3...25,3; 4,0...25,3 (LPG) kW	heat input (Hi) drinking water: 3,3...30,3 kW; 4,0...30,3 kW (LPG)
VCW 356/5-7 (E-PL) ecoTEC exclusive	nominal heat output: 3,4...24,6; 7,6...24,6 (LPG) kW heat input (Hi): 3,6...24,8; 8,0...24,8 (LPG) kW	heat input (Hi) drinking water: 3,6...32,7 kW; 8,0...32,7 kW (LPG)

Hints of Utilization /Remarks
Verwendungshinweise / Bemerkungen

Flue types B23, B23P, B33, B33P, B53, B53P, C13, C33, C43, C53, C83 and C93: according to installation manual 0020159912